

**IP65 Test Report -  Before production  After production**


To : Sheenly Lighting Co., Ltd.  
Attn : Byron.zhang

Tel : (+86)21-64116358  
Fax : (+86)21-64113138  
ext.632

Supplier : Sheenly Lighting Co., Ltd.  
Manufacturer Name : Sheenly Lighting Co., Ltd.  
Manufacturer Location : No.2755 Sanlu Road,Bldg1,Minhang District,Shanghai,China

Product type : LED high bay

Model name : SL-BAY-230W-NW-AN



European EC directives : Low Voltage Directive: 2006/95/EC

Applicable standards : EN 60598-1:2008+A11:2009

Documents provided : Dekra test report 3147904.50A

Samples picked by : -- on : --

Samples received in DEKRA Laboratory on : 2014-06-05

Amount of samples received : 1 pc

Clauses checked : Class 9.2.2 and 9.2.6

Tests performed : IP65 test on 1 sample

This Document includes : 6 pages

Date of Construction Check : 2014-06-06

**Result : Pass**

**DEKRA Testing and Certification (Shanghai) Ltd**

10/F, #250, Jiangchangsan Road building  
16 Headquater Economy Park  
Shibei Hi-Tech Park, Zhabei District  
Shanghai, 200233, P.R. China  
Tel: +86 21 60567666  
Fax: F + 86 21 6056 7555

**PRODUCT DATA**

			Remarks
Type of lamp	:	LED	--
Rated frequency	:	50/60 Hz	--
Degree of protection	:	IP65	--
Cord attachment type	:	--	--
Accessories provided	:	--	--
Class	:	I	--

**RATING LABEL**

On enclosure

**SHEENLY**

Part Number: **SL-BAY-230W-NW-AN**

Rated Voltage: **100-240VAC, 50/60Hz**

Wattage: **230W 0.9A**



Note:

- The height of graphical symbols shall not be less than 5 mm. The height of letters and numerals either shown separately or with or as part of symbols shall not be less than 2 mm.
- The CE marking must have substantially the same vertical dimension, which may not be less than 5 mm.
- The symbol combination of WEEE logo shall have a minimum height of 7 mm.
- F mark is not mandatory.

**DEKRA Testing and Certification (Shanghai) Ltd**

10/F, #250, Jiangchangsan Road building  
 16 Headquarter Economy Park  
 Shibei Hi-Tech Park, Zhabei District  
 Shanghai, 200233, P.R. China  
 Tel: +86 21 60567666  
 Fax: F + 86 21 6056 7555

**Notes:**

- The product is without electronic control gear and it is deemed to comply with the requirements of IEC/EN 62493 without testing
- The product is deemed to comply with the requirements of EN 62493:2010. The test result was laid in test report 3147411.10 issued by DEKRA
- The product is classified as  Exempt group /  Risk group 1 /  Risk group 2 according to EN 62471-1:2008 and IEC/TR 61347-2:2009. The test result was laid in test report 3147410.50A and 3147410.50B issued by DEKRA

**DEKRA Testing and Certification (Shanghai) Ltd**

10/F, #250, Jiangchangsan Road building  
16 Headquater Economy Park  
Shibei Hi-Tech Park, Zhabei District  
Shanghai, 200233, P.R. China  
Tel: +86 21 60567666  
Fax: F + 86 21 6056 7555

**RESULTS**

Function	OK
Packaging	--
Cosmetic	--

**EN 60598-1**

CLAUSES	CONTENTS	PASS	FAIL	REMARK	NR
0	General introduction				X
3	Marking				X
4	Construction				X
5	External and internal wiring				X
7	Provision for earthing				X
8	Protection against electric shock				X
9	Resistance to dust , solid objects and moisture	X			
10	Insulation resistance and electric strength				X
11	Creepage distances and clearances				X

	Report review				X
--	---------------	--	--	--	---

**DEKRA Testing and Certification (Shanghai) Ltd**

10/F, #250, Jiangchangsan Road building  
 16 Headquarter Economy Park  
 Shibei Hi-Tech Park, Zhabei District  
 Shanghai, 200233, P.R. China  
 Tel: +86 21 60567666  
 Fax: F + 86 21 6056 7555

Please note that every statement made in this report is only valid for the samples tested and reported herein.

Trusting to have informed you sufficiently, we remain,  
With best regards

DEKRA Testing and Certification (Shanghai) Ltd.

**Engineer name** : Jingyi Yang      **Engineer signature** :



**Reviewed by** : Astro Ma      **Reviewer signature** :






Sample notice:

The appliance(s) will be kept in our laboratory for a period of one month. After this time, we will dispose it (them) accordingly.

**DEKRA Testing and Certification (Shanghai) Ltd**

10/F, #250, Jiangchangsan Road building  
16 Headquater Economy Park  
Shibei Hi-Tech Park, Zhabei District  
Shanghai, 200233, P.R. China  
Tel: +86 21 60567666  
Fax: F + 86 21 6056 7555

Pictures of Sample	
	
Overview	Overview
	--
Gland	--

**DEKRA Testing and Certification (Shanghai) Ltd**

10/F, #250, Jiangchangsan Road building  
 16 Headquater Economy Park  
 Shibe Hi-Tech Park, Zhabei District  
 Shanghai, 200233, P.R. China  
 Tel: +86 21 60567666  
 Fax: F + 86 21 6056 7555